

Central Coast Water Authority



Process Control Benchsheet

Date: Monday, January 5, 2026

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity mg/L as CaCO3	Hardness	Nitrate mg/L as N	Nitrite	TON	TDS	Coliform	December Deliveries
				Total	Free	Total	Free								
Treated Water Tanks	12.6	8.25	0.08	3.45		0.73	0.01	68	98	0.4	0.005	1	280	Absent	
Shandon T/O															0
Tank Site #2	13.0	8.35	0.07	3.20		0.67	0.06	70	98	0.7	0.005	1	285	Absent	
Chorro															124
Lopez T/O															0
Guadalupe T/O	16.1	8.46	0.07	2.94		0.65	0.09	74	106	0.7	0.006	1	298	Absent	32
Santa Maria T/O	15.9	8.47	0.06	2.88		0.66	0.10	76	106	0.6	0.006	1	301	Absent	342
Golden State T/O															5
Tank Site #5	16.2	8.44	0.08	2.54		0.61	0.14	78	110	0.7	0.012	1	312	Absent	
Vandenberg T/O	15.9	8.47	0.07	2.81		0.53	0.00	80	108	0.6	0.006	1	311	Absent	227
Tank Site #7	17.1	8.98	0.06	1.37		0.33	0.02	78	110	0.5	0.008	1	362	Absent	
Buellton T/O															0
Solvang T/O															0
Santa Ynex ID#1 T/O															0

Average Plant Flow for Sample Week = 7.3 MG

Samples Taken: 01/05/2026
 Samples Analyzed: 1/8/2026 10:47:00 AM
 Sampler: James Thompson, Sean Rogi
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 01/09/2026

Central Coast Water Authority



Process Control Benchsheet

Date: Monday, January 12, 2026

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity Hardness		Nitrate	Nitrite	TON	TDS	Coliform	December Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N						
<i>Treated Water Tanks</i>	11.5	8.23	0.05	3.42		0.67	0.02	68	102	0.8	0.006	1	293	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	13.2	8.29	0.07	3.11		0.68	0.08	82	102	0.8	0.005	1	292	Absent	
<i>Chorro</i>	14.5	8.36	0.05	3.09		0.65	0.05	78	102	0.7	0.006	1	288	Absent	124
<i>Lopez T/O</i>	16.2	8.38	0.06	2.89		0.63	0.07	74	100	0.5	0.005	1	286	Absent	0
<i>Guadalupe T/O</i>	16.5	8.46	0.07	2.90		0.64	0.08	72	100	0.5	0.006	1	285	Absent	32
<i>Santa Maria T/O</i>	16.5	8.45	0.07	2.83		0.64	0.09	70	100	0.4	0.007	1	284	Absent	342
<i>Golden State T/O</i>															5
<i>Tank Site #5</i>	16.4	8.48	0.06	2.49		0.56	0.09	70	100	0.4	0.016	1	283	Absent	
<i>Vandenberg T/O</i>	16.6	8.45	0.06	2.76		0.52	0.00	70	104	0.4	0.006	1	285	Absent	227
<i>Tank Site #7</i>	16.6	8.94	0.07	1.35		0.31	0.05	74	108	0.4	0.005	1	362	Absent	
<i>Buellton T/O</i>															0
<i>Solvang T/O</i>															0
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 8.0 MG

Samples Taken: 01/12/2026
 Samples Analyzed: 1/15/2026 11:58:00 AM
 Sampler: James Thompson, Sean Rogi
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 01/15/2026

Central Coast Water Authority



Process Control Benchsheet

Date: Tuesday, January 20, 2026

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity Hardness		Nitrate	Nitrite	TON	TDS	Coliform	December Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N						
<i>Treated Water Tanks</i>	12.4	8.19	0.05	3.32		0.73	0.05	74	116	0.4	0.006	1	333	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	12.8	8.28	0.07	3.09		0.60	0.06	76	112	0.4	0.006	1	313	Absent	
<i>Chorro</i>	14.0	8.33	0.09	3.06		0.61	0.09	74	108	0.3	0.005	1	311	Absent	124
<i>Lopez T/O</i>	14.7	8.37	0.07	2.99		0.57	0.06	72	108	0.3	0.006	1	306	Absent	0
<i>Guadalupe T/O</i>	15.6	8.40	0.05	2.86		0.64	0.08	70	108	0.3	0.006	1	301	Absent	32
<i>Santa Maria T/O</i>	15.7	8.38	0.06	2.72		0.63	0.08	70	106	0.3	0.005	1	300	Absent	342
<i>Golden State T/O</i>															5
<i>Tank Site #5</i>	16.1	8.38	0.07	2.36		0.55	0.10	70	106	0.4	0.016	1	296	Absent	
<i>Vandenberg T/O</i>	15.9	8.38	0.05	2.61		0.50	0.00	72	108	0.4	0.006	1	296	Absent	227
<i>Tank Site #7</i>	17.0	8.85	0.06	1.06		0.33	0.12	72	110	0.4	0.010	1	362	Absent	
<i>Buellton T/O</i>															0
<i>Solvang T/O</i>															0
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 7.3 MG

Samples Taken: 01/20/2026
 Samples Analyzed: 1/22/2026 10:40:00 AM
 Sampler: David Bazzell, Sean Rogers
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 01/23/2026

Central Coast Water Authority



Process Control Benchsheet

Date: Monday, January 26, 2026

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity mg/L as CaCO3	Hardness	Nitrate mg/L as N	Nitrite TON	TDS	Coliform	December Deliveries	
				Total	Free	Total	Free								
<i>Treated Water Tanks</i>	12.3	8.32	0.08	3.40		0.72	0.01	66	106	0.4	0.005	1	317	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	12.8	8.26	0.08	3.07		0.62	0.09	74	112	0.5	0.004	1	341	Absent	
<i>Chorro</i>	14.0	8.30	0.07	2.98		0.58	0.08	74	122	0.5	0.005	1	345	Absent	124
<i>Lopez T/O</i>	14.6	8.36	0.06	2.98		0.60	0.09	76	120	0.4	0.005	1	345	Absent	0
<i>Guadalupe T/O</i>	15.9	8.39	0.08	2.84		0.64	0.09	76	120	0.4	0.006	1	341	Absent	32
<i>Santa Maria T/O</i>	16.7	8.42	0.06	2.84		0.63	0.08	76	118	0.4	0.005	1	337	Absent	342
<i>Golden State T/O</i>															5
<i>Tank Site #5</i>	15.4	8.41	0.06	2.41		0.56	0.12	74	114	0.4	0.027	1	323	Absent	
<i>Vandenberg T/O</i>	15.5	8.42	0.05	2.69		0.54	0.03	74	112	0.3	0.010	1	318	Absent	227
<i>Tank Site #7</i>	15.9	8.84	0.07	0.91		0.30	0.11	72	110	0.4	0.022	1	363	Absent	
<i>Buellton T/O</i>															0
<i>Solvang T/O</i>															0
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 7.5 MG

Samples Taken: 01/26/2026
 Samples Analyzed: 1/27/2026 1:32:00 PM
 Sampler: Adrian Arguilles, Sean Roger
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 01/29/2026

Central Coast Water Authority



Process Control Benchsheet

Date: Monday, February 2, 2026

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity Hardness		Nitrate	Nitrite	TON	TDS	Coliform	January Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N						
Treated Water Tanks	13.9	8.19	0.09	3.38		0.73	0.05	66	104	0.6	0.005	1	305	Absent	
Shandon T/O															0
Tank Site #2	12.9	8.31	0.08	3.07		0.61	0.08	64	102	0.6	0.006	1	307	Absent	
Chorro	14.1	8.34	0.09	2.94		0.58	0.09	66	102	0.5	0.005	1	306	Absent	120
Lopez T/O	14.8	8.37	0.07	2.91		0.55	0.05	66	102	0.5	0.004	1	307	Absent	20
Guadalupe T/O	16.4	8.43	0.06	2.79		0.62	0.08	66	104	0.4	0.005	1	309	Absent	19
Santa Maria T/O	16.2	8.42	0.07	2.81		0.63	0.10	66	106	0.4	0.006	1	311	Absent	349
Golden State T/O															1
Tank Site #5	15.7	8.41	0.09	2.50		0.59	0.11	68	108	0.4	0.014	1	320	Absent	
Vandenberg T/O	15.5	8.36	0.07	2.98		0.55	0.03	68	108	0.4	0.011	1	328	Absent	226
Tank Site #7	15.4	8.82	0.06	0.72		0.26	0.10	72	106	0.5	0.066	1	364	Absent	
Buellton T/O															0
Solvang T/O															0
Santa Ynex ID#1 T/O															0

Average Plant Flow for Sample Week = 8.9 MG

Samples Taken: 02/02/2026
 Samples Analyzed: 2/5/2026 12:23:00 PM
 Sampler: Cody Weinberg, Sean Roger
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 02/06/2026

Central Coast Water Authority



Process Control Benchsheet

Date: Monday, February 9, 2026

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity mg/L as CaCO3	Hardness	Nitrate mg/L as N	Nitrite mg/L as N	TON	TDS	Coliform	January Deliveries
				Total	Free	Total	Free								
Treated Water Tanks	14.0	8.21	0.06	3.20		0.67	0.00	70	102	0.8	0.005	1	280	Absent	
Shandon T/O															0
Tank Site #2	13.3	8.27	0.08	2.91		0.60	0.09	68	102	0.9	0.005	1	293	Absent	
Chorro	14.4	8.33	0.07	2.91		0.60	0.09	70	104	0.8	0.007	1	298	Absent	120
Lopez T/O	14.8	8.34	0.07	2.78		0.58	0.10	70	100	0.7	0.007	1	302	Absent	20
Guadalupe T/O	15.6	8.38	0.07	2.76		0.64	0.10	70	96	0.6	0.006	1	306	Absent	19
Santa Maria T/O	15.7	8.40	0.06	2.67		0.64	0.11	72	100	0.5	0.006	1	307	Absent	349
Golden State T/O															1
Tank Site #5	15.7	8.40	0.06	2.34		0.56	0.12	70	104	0.5	0.021	1	309	Absent	
Vandenberg T/O	15.6	8.39	0.08	2.61		0.52	0.02	68	106	0.4	0.009	1	311	Absent	226
Tank Site #7	16.9	8.70	0.06	0.39		0.10	0.04	74	108	0.5	0.199	1	364	Absent	
Buellton T/O															0
Solvang T/O															0
Santa Ynex ID#1 T/O															0

Average Plant Flow for Sample Week = 6.8 MG

Samples Taken: 02/09/2026

Samples Analyzed: 2/12/2026 10:38:00 AM

Sampler: David Bazzell, Sean Rogers

Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 02/18/2026

Central Coast Water Authority



Process Control Benchsheet

Date: *Tuesday, February 17, 2026*

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity Hardness		Nitrate mg/L as N	Nitrite mg/L as N	TON	TDS	Coliform	January Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as CaCO3						
<i>Treated Water Tanks</i>	12.8	8.36	0.05	3.29		0.73	0.05	70	92	1.0	0.007	1	251	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	13.7	8.31	0.06	3.00		0.70	0.13	70	98	1.1	0.005	1	260	Absent	
<i>Chorro</i>															120
<i>Lopez T/O</i>	14.8	8.41	0.07	2.92		0.66	0.14	74	96	1.0	0.006	1	264	Absent	20
<i>Guadalupe T/O</i>	15.6	8.46	0.07	2.69		0.68	0.15	76	100	0.9	0.007	1	269	Absent	19
<i>Santa Maria T/O</i>	15.8	8.43	0.10	2.61		0.66	0.12	76	100	0.9	0.007	1	272	Absent	349
<i>Golden State T/O</i>															1
<i>Tank Site #5</i>	15.6	8.45	0.08	2.24		0.58	0.14	78	102	0.8	0.033	1	279	Absent	
<i>Vandenberg T/O</i>	14.4	8.43	0.10	2.62		0.52	0.02	78	102	0.8	0.009	1	283	Absent	226
<i>Tank Site #7</i>	16.2	8.69	0.11	0.04		0.03	0.02	80	108	0.5	0.241	1	364	Absent	
<i>Buellton T/O</i>															0
<i>Solvang T/O</i>															0
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 7.9 MG

Samples Taken: 02/17/2026
 Samples Analyzed: 2/18/2026 2:37:00 PM
 Sampler: James Shaner, Sean Rogers
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 02/20/2026

Central Coast Water Authority



Process Control Benchsheet

Date: Monday, March 2, 2026

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity mg/L as CaCO3	Hardness	Nitrate mg/L as N	Nitrite mg/L as N	TON	TDS	Coliform	February Deliveries
				Total	Free	Total	Free								
Treated Water Tanks	15.7	8.32	0.10	3.53		0.73	0.02	70	86	1.1	0.005	1	222	Absent	
Shandon T/O															0
Tank Site #2	14.3	8.30	0.06	3.20		0.61	0.05	74	90	1.1	0.006	1	234	Absent	
Chorro	14.9	8.36	0.12	3.11		0.57	0.06	80	94	1.1	0.005	1	238	Absent	134
Lopez T/O	15.1	8.37	0.06	3.02		0.59	0.08	82	94	1.0	0.006	1	241	Absent	105
Guadalupe T/O	15.4	8.44	0.08	2.95		0.69	0.11	82	94	1.0	0.008	1	245	Absent	15
Santa Maria T/O	15.4	8.40	0.11	2.92		0.68	0.10	80	92	1.0	0.007	1	245	Absent	306
Golden State T/O															0
Tank Site #5	15.5	8.29	0.09	2.03		0.49	0.12	80	92	1.0	0.044	1	240	Absent	
Vandenberg T/O	15.1	8.28	0.08	2.25		0.43	0.02	80	92	1.0	0.007	1	241	Absent	206
Tank Site #7															
Buellton T/O															0
Solvang T/O															0
Santa Ynex ID#1 T/O															0

Average Plant Flow for Sample Week = 10.5 MG

Samples Taken: 03/02/2026
 Samples Analyzed: 3/3/2026 3:02:00 PM
 Sampler: Adrian Arguilles, Sean Roger
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 03/10/2026

Central Coast Water Authority



Process Control Benchsheet

Date: Monday, March 9, 2026

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity mg/L as CaCO3	Hardness	Nitrate mg/L as N	Nitrite	TON	TDS	Coliform	February Deliveries
				Total	Free	Total	Free								
<i>Treated Water Tanks</i>	17.0	8.23	0.06	3.31		0.73	0.04	66	80	1.1	0.006	1	204	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	15.3	8.29	0.06	3.13		0.65	0.05	68	82	1.3	0.005	1	208	Absent	
<i>Chorro</i>	15.9	8.34	0.08	3.03		0.62	0.00	68	82	1.2	0.006	1	209	Absent	134
<i>Lopez T/O</i>	16.2	8.38	0.07	2.92		0.61	0.08	70	84	1.1	0.006	1	212	Absent	105
<i>Guadalupe T/O</i>	16.5	8.41	0.11	2.81		0.65	0.10	72	86	1.0	0.006	1	215	Absent	15
<i>Santa Maria T/O</i>	16.4	8.40	0.11	2.80		0.64	0.09	74	86	1.0	0.006	1	215	Absent	306
<i>Golden State T/O</i>															0
<i>Tank Site #5</i>	16.0	8.35	0.07	2.01		0.50	0.13	76	88	1.0	0.057	1	223	Absent	
<i>Vandenberg T/O</i>	15.3	8.31	0.07	2.13		0.41	0.03	76	88	1.0	0.007	1	228	Absent	206
<i>Tank Site #7</i>															
<i>Buellton T/O</i>															0
<i>Solvang T/O</i>															0
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 9.2 MG

Samples Taken: 03/09/2026
 Samples Analyzed: 3/12/2026 8:20:00 AM
 Sampler: Cody Weinberg, Joe Parent
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 03/12/2026

Central Coast Water Authority



Process Control Benchsheet

Date: Monday, March 16, 2026

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity Hardness		Nitrate mg/L as N	Nitrite mg/L as N	TON	TDS	Coliform	February Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as CaCO3						
<i>Treated Water Tanks</i>	19.0	8.39	0.05	3.25		0.65	0.01	62	78	1.0	0.006	1	209	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	16.2	8.35	0.07	2.96		0.55	0.05	64	80	1.2	0.005	1	208	Absent	
<i>Chorro</i>	16.9	8.38	0.08	2.86		0.73	0.16	66	82	1.2	0.007	1	208	Absent	134
<i>Lopez T/O</i>	17.2	8.40	0.07	2.87		0.53	0.09	66	82	1.1	0.007	1	208	Absent	105
<i>Guadalupe T/O</i>	17.5	8.42	0.09	2.75		0.64	0.10	66	82	1.1	0.007	1	207	Absent	15
<i>Santa Maria T/O</i>	17.3	8.41	0.07	2.72		0.63	0.09	64	84	1.1	0.007	1	207	Absent	306
<i>Golden State T/O</i>															0
<i>Tank Site #5</i>	17.3	8.30	0.07	1.83		0.47	0.14	62	84	1.2	0.081	1	208	Absent	
<i>Vandenberg T/O</i>	16.6	8.25	0.06	1.93		0.38	0.03	66	82	1.2	0.006	1	210	Absent	206
<i>Tank Site #7</i>															
<i>Buellton T/O</i>															0
<i>Solvang T/O</i>															0
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 8.8 MG

Samples Taken: 03/16/2026
 Samples Analyzed: 3/17/2026 2:12:00 PM
 Sampler: James Thompson, Sean Rogi
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 03/19/2026

Central Coast Water Authority



Process Control Benchsheet

Date: *Monday, March 23, 2026*

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity Hardness		Nitrate mg/L as N	Nitrite mg/L as N	TON	TDS	Coliform	February Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as CaCO3						
<i>Treated Water Tanks</i>	21.2	8.36	0.06	3.53		0.72	0.01	60	76	0.8	0.005	1	201	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	18.8	8.35	0.08	3.13		0.60	0.08	62	80	1.2	0.006	1	204	Absent	
<i>Chorro</i>	18.9	8.37	0.08	3.07		0.55	0.04	64	82	1.2	0.006	1	205	Absent	134
<i>Lopez T/O</i>	19.0	8.40	0.06	2.94		0.58	0.10	64	82	1.0	0.006	1	206	Absent	105
<i>Guadalupe T/O</i>	18.7	8.48	0.06	2.81		0.66	0.10	66	82	1.0	0.009	1	207	Absent	15
<i>Santa Maria T/O</i>	18.7	8.47	0.06	2.81		0.65	0.10	66	82	0.9	0.010	1	207	Absent	306
<i>Golden State T/O</i>															0
<i>Tank Site #5</i>	18.1	8.37	0.05	1.67		0.38	0.11	66	82	1.1	0.087	1	210	Absent	
<i>Vandenberg T/O</i>	17.9	8.33	0.07	1.60		0.30	0.03	68	82	1.1	0.008	1	212	Absent	206
<i>Tank Site #7</i>															
<i>Buellton T/O</i>															0
<i>Solvang T/O</i>															0
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 9.4 MG

Samples Taken: 03/23/2026
 Samples Analyzed: 3/26/2026 10:39:00 AM
 Sampler: James Shaner, Sean Rogers
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 04/01/2026

Central Coast Water Authority



Process Control Benchsheet

Date: *Monday, March 30, 2026*

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity Hardness		Nitrate	Nitrite	TON	TDS	Coliform	February Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N						
<i>Treated Water Tanks</i>	21.2	8.27	0.06	3.43		0.68	0.01	66	80	0.6	0.004	1	204	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	20.0	8.35	0.06	3.17		0.62	0.07	68	82	0.8	0.005	1	205	Absent	
<i>Chorro</i>	20.4	8.37	0.08	3.05		0.61	0.05	70	84	0.8	0.005	1	205	Absent	134
<i>Lopez T/O</i>	20.5	8.41	0.07	3.04		0.60	0.09	72	82	0.7	0.005	1	204	Absent	105
<i>Guadalupe T/O</i>	20.4	8.44	0.09	2.90		0.64	0.08	74	80	0.6	0.012	1	205	Absent	15
<i>Santa Maria T/O</i>	20.1	8.44	0.07	2.77		0.62	0.07	74	80	0.6	0.017	1	205	Absent	306
<i>Golden State T/O</i>															0
<i>Tank Site #5</i>	19.2	8.20	0.13	1.43		0.35	0.12	74	80	0.8	0.117	1	205	Absent	
<i>Vandenberg T/O</i>	18.6	8.20	0.08	1.45		0.28	0.04	74	82	0.8	0.007	1	208	Absent	206
<i>Tank Site #7</i>															
<i>Buellton T/O</i>															0
<i>Solvang T/O</i>															0
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 12.2 MG

Samples Taken: 03/30/2026
 Samples Analyzed: 3/31/2026 1:13:00 PM
 Sampler: David Bazzell, Sean Rogers
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 04/02/2026

Central Coast Water Authority



Process Control Benchsheet

Date: Monday, April 6, 2026

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity mg/L as CaCO3	Hardness	Nitrate mg/L as N	Nitrite mg/L as N	TON	TDS	Coliform	March Deliveries
				Total	Free	Total	Free								
<i>Treated Water Tanks</i>	21.1	8.21	0.04	3.45		0.75	0.05	64	80	0.7	0.006	1	206	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	18.9	8.33	0.09	3.24		0.64	0.10	66	80	0.8	0.006	1	208	Absent	
<i>Chorro</i>	19.6	8.38	0.06	3.21		0.61	0.08	70	80	0.7	0.006	1	210	Absent	130
<i>Lopez T/O</i>	19.9	8.38	0.05	3.11		0.59	0.07	70	82	0.7	0.007	1	211	Absent	138
<i>Guadalupe T/O</i>	20.8	8.39	0.05	2.87		0.66	0.10	72	82	0.6	0.018	1	212	Absent	18
<i>Santa Maria T/O</i>	21.1	8.35	0.06	2.88		0.63	0.11	70	82	0.6	0.035	1	212	Absent	435
<i>Golden State T/O</i>															0
<i>Tank Site #5</i>	19.7	8.17	0.08	1.64		0.32	0.12	68	82	0.7	0.121	1	210	Absent	
<i>Vandenberg T/O</i>	18.5	8.18	0.06	1.29		0.26	0.06	68	82	0.7	0.009	1	212	Absent	257
<i>Tank Site #7</i>															
<i>Buellton T/O</i>															0
<i>Solvang T/O</i>															0
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 12.3 MG

Samples Taken: 04/06/2026
 Samples Analyzed: 4/8/2026 10:47:00 AM
 Sampler: Adrian Arguilles, Sean Roger
 Analyst: Sean Rogers

Comments: Chlorination system on at Tank 5.

Report Generated: 04/17/2026

Central Coast Water Authority



Process Control Benchsheet

Date: Monday, April 13, 2026

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity Hardness		Nitrate	Nitrite	TON	TDS	Coliform	March Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N						
<i>Treated Water Tanks</i>	18.6	8.38	0.05	3.34		0.69	0.00	66	80	0.5	0.006	1	213	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	18.5	8.32	0.05	2.72		0.50	0.06	72	82	0.8	0.006	1	210	Absent	
<i>Chorro</i>	19.1	8.38	0.06	2.70		0.54	0.10	70	82	0.8	0.005	1	209	Absent	130
<i>Lopez T/O</i>	19.1	8.47	0.06	2.68		0.57	0.12	70	82	0.7	0.006	1	209	Absent	138
<i>Guadalupe T/O</i>	19.5	8.57	0.09	2.71		0.66	0.14	70	82	0.7	0.012	1	210	Absent	18
<i>Santa Maria T/O</i>	19.6	8.53	0.07	2.67		0.66	0.12	68	82	0.6	0.016	1	210	Absent	435
<i>Golden State T/O</i>															0
<i>Tank Site #5</i>	19.0	8.54	0.07	2.58		0.62	0.14	68	84	0.6	0.038	1	210	Absent	
<i>Vandenberg T/O</i>	18.6	8.52	0.05	3.09		0.60	0.03	70	84	0.6	0.015	1	212	Absent	257
<i>Tank Site #7</i>	17.9	8.54	0.07	2.09		0.41	0.00	68	84	0.6	0.009	1	217	Absent	
<i>Buellton T/O</i>	18.2	8.48	0.06	1.32		0.25	0.00	66	84	0.7	0.007	1	218	Absent	0
<i>Solvang T/O</i>	17.2	8.39	0.36	1.02		0.19	0.03	66	86	0.7	0.007	1	220	Absent	0
<i>Santa Ynex ID#1 T/O</i>	17.0	8.42	0.09	0.65		0.15	0.04	64	86	0.8	0.014	1	224	Absent	0

Average Plant Flow for Sample Week = 5.3 MG

Samples Taken: 04/13/2026
 Samples Analyzed: 4/16/2026 8:27:00 AM
 Sampler: Cody Weinberg, Sean Roger
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7.

Report Generated: 04/17/2026

Central Coast Water Authority



Process Control Benchsheet

Date: Monday, April 20, 2026

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity mg/L as CaCO3	Hardness	Nitrate mg/L as N	Nitrite	TON	TDS	Coliform	March Deliveries
				Total	Free	Total	Free								
<i>Treated Water Tanks</i>	19.7	8.28	0.05	3.39		0.71	0.02	72	88	0.5	0.005	1	233	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	18.8	8.38	0.05	3.12		0.64	0.09	70	88	0.6	0.005	1	231	Absent	
<i>Chorro</i>	19.3	8.40	0.06	3.10		0.56	0.04	70	88	0.6	0.007	1	229	Absent	130
<i>Lopez T/O</i>	19.6	8.40	0.06	3.06		0.56	0.07	70	86	0.6	0.006	1	227	Absent	138
<i>Guadalupe T/O</i>	20.1	8.42	0.06	2.97		0.65	0.11	68	86	0.5	0.019	1	221	Absent	18
<i>Santa Maria T/O</i>	20.5	8.38	0.06	2.86		0.62	0.09	68	86	0.5	0.028	1	219	Absent	435
<i>Golden State T/O</i>															0
<i>Tank Site #5</i>	19.0	8.33	0.06	2.29		0.46	0.10	68	84	0.5	0.074	1	218	Absent	
<i>Vandenberg T/O</i>	18.9	8.32	0.05	2.15		0.39	0.03	70	84	0.5	0.008	1	220	Absent	257
<i>Tank Site #7</i>	17.5	8.57	0.05	2.68		0.52	0.00	68	84	0.6	0.009	1	213	Absent	
<i>Buellton T/O</i>															0
<i>Solvang T/O</i>	16.9	8.58	0.08	2.47		0.52	0.04	66	84	0.6	0.008	1	213	Absent	0
<i>Santa Ynex ID#1 T/O</i>															0

Average Plant Flow for Sample Week = 11.7 MG

Samples Taken: 04/20/2026
 Samples Analyzed: 4/23/2026 11:31:00 AM
 Sampler: James Thompson, Sean Rogi
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7. SYPP pumped 35.79 acre-feet to Lake Cachuma.

Report Generated: 05/01/2026

Central Coast Water Authority



Process Control Benchsheet

Date: Monday, April 27, 2026

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity mg/L as CaCO3	Hardness	Nitrate mg/L as N	Nitrite	TON	TDS	Coliform	March Deliveries
				Total	Free	Total	Free								
<i>Treated Water Tanks</i>	17.8	8.33	0.05	3.73		0.79	0.05	70	88	0.8	0.004	1	228	Absent	
<i>Shandon T/O</i>															0
<i>Tank Site #2</i>	18.3	8.33	0.06	3.37		0.63	0.05	76	90	0.5	0.005	1	231	Absent	
<i>Chorro</i>	19.2	8.40	0.06	3.32		0.60	0.04	76	90	0.5	0.005	1	232	Absent	130
<i>Lopez T/O</i>	19.2	8.41	0.07	3.30		0.70	0.13	76	90	0.4	0.006	1	232	Absent	138
<i>Guadalupe T/O</i>	19.9	8.39	0.09	3.15		0.66	0.09	78	92	0.4	0.020	1	233	Absent	18
<i>Santa Maria T/O</i>	20.0	8.36	0.05	3.02		0.64	0.09	80	92	0.4	0.029	1	233	Absent	435
<i>Golden State T/O</i>															0
<i>Tank Site #5</i>	19.7	8.25	0.05	2.37		0.50	0.10	78	90	0.5	0.057	1	234	Absent	
<i>Vandenberg T/O</i>	19.3	8.24	0.09	2.45		0.46	0.07	78	90	0.5	0.006	1	236	Absent	257
<i>Tank Site #7</i>	18.6	8.32	0.04	2.07		0.40	0.02	80	92	0.5	0.006	1	238	Absent	
<i>Buellton T/O</i>															0
<i>Solvang T/O</i>	18.8	8.36	0.05	1.95		0.39	0.02	84	90	0.5	0.005	1	238	Absent	0
<i>Santa Ynex ID#1 T/O</i>	18.6	8.38	0.04	1.87		0.39	0.01	74	90	0.5	0.006	1	238	Absent	0

Average Plant Flow for Sample Week = 14.7 MG

Samples Taken: 04/27/2026
 Samples Analyzed: 4/30/2026 11:09:00 AM
 Sampler: James Shaner, Sean Rogers
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7.

Report Generated: 05/01/2026