

# Central Coast Water Authority



## Process Control Benchsheet

Date: Monday, January 3, 2022

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity	Hardness	Nitrate	Nitrite	TON	TDS	Coliform	December Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N	mg/L as N					
Treated Water Tanks	12.4	8.24	0.10	2.90		0.65	0.02	78	108	0.5	0.008	1	390	Absent	
Shandon T/O															
Tank Site #2	12.0	8.29	0.10	2.87		0.64	0.06	82	114	0.4	0.009	1	394	Absent	
Chorro	13.3	8.32	0.14	2.87		0.64	0.08	80	112	0.4	0.008	1	394	Absent	
Lopez T/O	14.6	8.31	0.11	2.64		0.62	0.10	82	118	0.4	0.007	1	398	Absent	
Guadalupe T/O															
Santa Maria T/O															
Golden State T/O															
Tank Site #5	16.1	8.44	0.10	2.03		0.51	0.10	84	122	0.5	0.019	1	404	Absent	
Vandenberg T/O															
Tank Site #7	16.2	8.42	0.12	2.37		0.44	0.00	84	122	0.5	0.011	1	410	Absent	
Buellton T/O															
Solvang T/O	16.4	8.48	0.12	2.37		0.46	0.00	84	124	0.5	0.009	1	412	Absent	
Santa Ynex ID#1 T/O															

Average Plant Flow for Sample Week = 6.4 MG

Samples Taken: 01/03/2022  
 Samples Analyzed: 1/5/2022 7:45:00 AM  
 Sampler: David Bazzell  
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7. SYPP pumped 51.15 acre-feet to Lake Cachuma.

Report Generated: 01/06/2022

# Central Coast Water Authority



## Process Control Benchsheet

Date: Monday, January 10, 2022

	Temp °C	pH	NTU	Chlorine (mg/L)		NH3-N (mg/L)		Alkalinity	Hardness	Nitrate	Nitrite	TON	TDS	Coliform	December Deliveries
				Total	Free	Total	Free	mg/L as CaCO3	mg/L as N	mg/L as N					
Treated Water Tanks	12.7	8.17	0.10	3.23		0.65	0.04	78	120	0.6	0.008	1	394	Absent	
Shandon T/O															0
Tank Site #2	11.8	8.24	0.12	2.89		0.64	0.08	82	118	0.4	0.009	1	392	Absent	
Chorro	13.1	8.27	0.13	2.81		0.61	0.07	82	120	0.4	0.009	1	392	Absent	165
Lopez T/O	14.1	8.29	0.12	2.71		0.56	0.05	84	120	0.4	0.009	1	395	Absent	157
Guadalupe T/O															1
Santa Maria T/O															14
Golden State T/O															0
Tank Site #5	15.2	8.50	0.10	2.44		0.55	0.06	82	122	0.4	0.016	1	395	Absent	
Vandenberg T/O															0
Tank Site #7	15.4	8.47	0.11	2.44		0.44	0.00	84	122	0.4	0.007	1	400	Absent	
Buellton T/O															0
Solvang T/O	15.7	8.48	0.10	2.23		0.44	0.00	84	120	0.4	0.010	1	400	Absent	32
Santa Ynex ID#1 T/O															0

Average Plant Flow for Sample Week = 7.6 MG

Samples Taken: 01/10/2022  
 Samples Analyzed: 1/12/2022 8:00:00 AM  
 Sampler: David Bazzell  
 Analyst: Sean Rogers

Comments: Chlorination systems on at Tank 5 and Tank 7. SYPP pumped 92.2 acre-feet to Lake Cachuma.

Report Generated: 01/18/2022